



ENVIRO LABS LIMITED

Rm 611-612, Hong Leong Plaza, 33 Lok Yip Rd, Fanling, NT, HK
Tel: (852) 2676 2983 Fax: (852) 2676 2860
e-mail: ell@envirolabs.com.hk
http://www.envirolabs.com.hk



TEST REPORT

JOB NO. : 809506
DATE OF ISSUE : 9 October 2008

PAGE: 1 of 1

1. Customer

Sporttler Ltd.
Flat D, 17/F., Nathan Commercial Bldg., Yaumatei, Kowloon
Attn: Mr. Yan Chun-wah

2. Sample Identification

Sample Description : 1 batch of water samples was received in ambient condition
Quantity of Sample : 2 x 1L in plastic bottles, 1 x 250mL in sterile glass bottle with sodium thiosulphate
Sampling : Conducted by the staff of the Enviro Labs Ltd.
Sampling Location : 橫台山新村康樂田園
Sampling Date : 30 Sep 2008
Received Date : 30 Sep 2008
Testing Period : 30 Sep – 5 Oct 2008

3. Test Methods

Parameters	Reference Methods
5-day Biochemical Oxygen Demand (BOD ₅)	APHA ¹ 20e 5210 B
Total Suspended Solids (TSS)	APHA ¹ 17e 2540 D
<i>E. coli</i>	DoE (1983) Sec 7.8 & 7.9

1. APHA Standard Methods for the Examination of Water and Wastewater

4. Test Results^a

Sample No.	Parameters	Test Results	Units
809506-1	BOD ₅	5.6	mg/L
809506-1	TSS	< 2.5	mg/L
809506-2	<i>E. coli</i>	Not Detected	Count/100mL

Note:

- Test results relate only to the items received
- Detection limit of *E. coli* is 1 count/100mL.

--- End of Report ---



APPROVED SIGNATORY :

Kenneth Kar Kin LAM
(Laboratory Manager)